



Water Inspection Requirements

Note to contractors and plumbers hooking up new services to the RAE Water and Sewer District.

Contractors must call to notify RAE Water personnel when a water or sewer connection to the main is being performed. Office number is 586-3930. Ken's cell phone is 581-2921.

Service Requirements

- Service line must have a minimum 6-foot bury to the inside of the footer.
- Service line and curb stop must be bedded with suitable bedding material.
- Service line must be at least 4 feet from air vents in crawl space.
- Service line must be 12-18 inches from floor or ground (horizontally) and 12-18 inches from the wall (vertically).
- No obstructions closer than 24 inches in front and 12 inches in back, as stated in the Uniform Plumbing Code.
- From curb stop run water line sized for building in HDPE-clearcore.
- Install a ball valve followed by an approved water meter (RAE provides the meter), followed by a Watts L 7 Dual Check, followed by another ball valve.
- Radio-read transmitter to be installed on the front or side of the house connected to the water meter with a 3-wire connection (RAE provides the transmitter).

Prior to water turn on

Final inspection of water plumbing is required by RAE Water. Please call 581-2921 to schedule an inspection.

- Curb stop must be accessible and raised (or lowered) to grade.